

UKCA – Safety declaration of conformity

Daikin Europe N.V.

declares under its sole responsibility that the products to which this declaration relates:

MTS: UATYA(30/40/50/60/70/80/90/100/110/120/140/150/160/180/190)BBAY1*,
MTS: UATYA(30/40/50/60/70/80/90/100/110/120/140/150/160/180/190)BFC2Y1*,
MTS: UATYA(30/40/50/60/70/80/90/100/110/120/140/150/160/180/190)BFC3Y1*,
MTO: 30***...*, 40***...*, 50***...*, 60***...*, 70***...*, 80***...*, 90***...*, 100***...*, 110***...*, 120***...*, 140***...*, 150***...*, 160***...*, 180***...*, 190***...*,
*= , , 1,2,3,...,9

are in conformity with the following directive(s) or regulation(s), provided that the products are used in accordance with our instructions:

- S.I. 2008/1597: Supply of Machinery (Safety) Regulations 2008*** as amended,
S.I. 2016/1091: Electromagnetic Compatibility Regulations 2016*
S.I. 2016/1105: Pressure Equipment (Safety) Regulations 2016**

following the provisions of: BS EN 60204-1: 2018, BS EN 61000-6-3: 2021, BS EN 61000-6-2: 2019, BS EN 378-2: 2016, IEC 60335-2-40: 2018,

* as set out in <A> and judged positively by according to the Certificate <C>.

** as set out in the Technical Construction File <D> and judged positively by <E> (Applied module <F>) according to the Certificate <G>. Risk category <H>. Also refer to next page.

*** Daikin Europe N.V. is authorised to compile the Technical Construction File.

Table with 2 columns: Code, Value. Rows: <A> --, --, <C> --, <D> --, <E> Bureau Veritas Italia S.p.A. (NB1370), <F> H, <G> --, <H> III

2P522682

UKCA – Safety declaration of conformity

continuation of previous page:

Design Specifications of the products to which this declaration relates:

Maximum allowable pressure (PS): **<K>** (bar)

Minimum/maximum allowable temperature (TS*):

* TSmin: Minimum temperature at low pressure side: **<L>** (°C)

* TSmax: Saturated temperature corresponding with the maximum allowable pressure (PS): **<M>** (°C)

Refrigerant: **<N>**

Setting of pressure safety device: **<P>** (bar)

Manufacturing number and manufacturing year: refer to model nameplate

<K>	PS	46 bar
<L>	TSmin	-20 °C
<M>	TSmax	150 °C
<N>		R32
<P>		44 bar

Name and address of the Notified body that judged positively on compliance with the Pressure Equipment (Safety) Regulations: **<Q>**

**<Q> Bureau Veritas Italia S.p.A.
Via Miramare 15,
20126 Milano (MI), Italy**

2P522682



Hiromitsu Iwasaki
Director
Ostend, 3rd of October 2022

DAIKIN EUROPE N.V.
Zandvoordestraat 300, B-8400 Oostende, Belgium